



EDUCATION DEPARTMENT
GOVERNMENT OF SIKKIM
GANGTOK

Memo No. - 131/SD/EO/EDM

Date - 25/03/2021

BUILDING SAFETY CERTIFICATE

This is to Certify that a physical inspection of **Kendriya Vidyalaya N.H.P.C. Singtam, in East Sikkim**, was conducted on 22th March 2021 by the field engineer of Education Department East-I, where it was found that the above mentioned school had a single building which comprised of two storeyed RCC structure where two floors from ground floor to first floor were being run for academic purposes, with 44 rooms including toilets, the built in plinth area is 77,885.28ft².

The visual inspection revealed that the columns, beams and slab had no cracks or shear stress of any kind, the partitions were also found to be free from cracks. Till date the School building have no significant damages and defects. Hence, the structure can be certified to be fairly safe.

This certificate is valid for a period of one year only from the date of issue.

Assistant Engineer, East-I
Education Department
Govt. of Sikkim

Divisional Engineer, East-I
Education Department
Govt. of Sikkim

1. Superintending Engineer,
2. Office copy