



SINGTAM FIRE STATION
SIKKIM FIRE & EMERGENCY SERVICE
[27°23'21.73"N 88°49'84.74"E]
Ph No. 03592-233722

NO: 03 /POL/SF&ES/27 /SFS.

Date: 20 /03 /2024

NO OBJECTION CERTIFICATE

Certified that the premises of Kendriya Vidyalaya VHP Singtam
Balutik East-Sikkim has been inspected by the Sikkim Fire & Emergency Service with respect to the implementation of inbuilt fire fighting/fire prevention/escape means and declares the premises fit.

Sikkim Fire & Emergency Service has No Objection in its occupation/utilization for the purpose of
Fresh Till for Fire Safety Certificate.

Subject to the following conditions:

1. All entrance and exit passages shall be kept free from obstructions and exit signage should be displayed clearly.
2. No loose / naked electric wiring shall be permitted in the premises.
3. No leaking / damage containers containing poison or highly inflammable liquid or solids shall be stored in the premises.
4. Use of naked flame for cooking or heating & storage of petrol/diesel and kerosene in the premises is strictly prohibited.
5. To minimize damage to life & property from fire, the following fire safety measures shall be installed and maintained in the premises.

- | | | | |
|------|-------------|--|--------------|
| i) | - | nos. of DCP type fire extinguishers of capacity | _____ |
| ii) | * <u>07</u> | nos. of ABC type fire extinguishers of capacity | <u>06 Kg</u> |
| iii) | - | nos. of AFFF type fire extinguishers of capacity | _____ |
| iv) | - | nos. of CO2 type fire extinguishers of capacity | _____ |

This NOC becomes void in the event of violation, removal, or dilution of any of the above conditions.

Note: Valid for one year from the date of issue.

B. R. NO: 2324N-11610-17247 Dated 20/03/2024.

Buttini
Officer-In-charge

Singtam Fire Station, Gangtok, Sikkim

Fire & Emergency Service
Fire Station Officer (FSO)
Fire & Emergency Service
Singtam, East Sikkim

To,
Mr./Mrs./Miss

Kendriya Vidyalaya
Balutik Singtam
East - Sikkim

Copy to:-

1. Director, Fire & Emergency Service – for kind information please.
2. Record file.